

## EU Declaration of Conformity

Number:	EU DoC P233b.docx
---------	-------------------

Manufacturer:	Johnson Controls Inc.
Address, City:	507 E. Michigan St. Milwaukee, WI 53202
Country:	USA
Phone number:	1-414-524-4500

***Certify and declare under our sole responsibility that the following:***

Description:	Adjustable differential pressure switch Differential pressure switch is used to sense flow of air, single or differential air pressure and can also be used to detect small positive gauge pressure or to detect a vacuum				
Product name:	P233 Sensitive Differential				
Brand:	Johnson Controls PENN				
<b>Identification</b>					
P232A-B-AAC	P233A-10-AAC	P233A-10-PAC	P233A-4-AAD	P233A-4-PAD	P233A-6-AAC
	P233A-10-AAD	P233A-10-PHC	P233A-4-AHC	P233A-4-PHC	P233A-6-AAD
	P233A-10-AHC	P233A-10-PKC	P233A-4-AKC	P233A-4-PKC	P233F-P3-AAC
	P233A-10-AKC	P233A-4-AAC	P233A-4-PAC	P233A-50-AAC	

***conforms with the essential requirements of the following directives:***

EMC Directive 2014/30/EU	Low Voltage Directive 2014/35/EU	Gas Appliance Directive 90/396/EEC	RoHS Directive 2011/65/EU
-----------------------------	-------------------------------------	---------------------------------------	------------------------------

***The following harmonised standards have been used in the assessment:***

EN 55014- 1:2006,A1:2009,A2:2011	EN 60730-1:2011 EN 60730-2-6:2008	EN 1854 – A1 : 1998	
	EN 60529:1989/A2:2013		

***and complies with the essential requirements and provisions of the Directives.***


***The following Notified Body has issued a positive Statement of Opinion:***

Identification of NB:	NB reference Letter of Opinion:	Name and address of Notified Body:
0063	Pressure Sensing Devices	Gastec Certification B.V.
	Compliance is based on examination to: EN 1854 : 1997 PIN 0063BM1788	Wilmesrdorf 50 7327 AC Apeldoorn The Netherlands

***The Technical documentation can by the Surveillance Authorities be requested at the following Single Point of Contact address:***

Company:	Johnson Controls Inc.
Address, City:	Westendhof 3, 45143 Essen
Country:	Germany

***Name and position of person authorised by the manufacturer:***

Apr 1, 2016 Date	 Roy M Rader, Director Engineering
---------------------	---