

DICHIARAZIONE DI CONFORMITÀ UE
EU DECLARATION OF CONFORMITY
DÉCLARATION UE DE CONFORMITÉ
EU- KONFORMITÄT SERKLÄRUNG

Art. 4.3

Il Costruttore

The Company
La società
Die Firma

Refrigera Industriale S.R.L.

Via Chiavornicco, 76
33084 CORDENONS (PN), ITALIA

dichiara che la
declares that the
déclare que la
erklärt dass die

valvola a sfera
ball valve
vanne à boisseau sphérique
Kugelabsperrentil

modello: type: model: Modell:

REF1.0.N/S.A.006.1(.M; .P; .T; .F14; .F38)	REF1.0.N/S.D.028.1(.M; .P; .T)	REF1.1.N/S.B.018.2(.52; .M.52; .P.52; .MP52)
REF1.0.N/S.A.006.2(.M; .P; .T; .F14; .F38)	REF1.0.N/S.D.028.2(.M; .P; .T)	REF1.1.N/S.C.022.3(.52; .M.52; .P.52; .MP52)
REF1.0.N/S.A.008.3(.M; .P; .T; .F14; .F38)	REF1.1.N/S.A.006.1(.52; .M.52; .P.52; .MP52)	REF1.1.N/S.D.028.1(.52; .M.52; .P.52; .MP52)
REF1.0.N/S.A.010.1(.M; .P; .T; .F14; .F38)	REF1.1.N/S.A.006.2(.52; .M.52; .P.52; .MP52)	REF1.1.N/S.D.028.2(.52; .M.52; .P.52; .MP52)
REF1.0.N/S.A.010.2(.M; .P; .T; .F14; .F38)	REF1.1.N/S.A.008.3(.52; .M.52; .P.52; .MP52)	REF1.0.N.A.006.4(.M; .P)
REF1.0.N/S.A.012.1(.M; .P; .T; .F14; .F38)	REF1.1.N/S.A.010.1(.52; .M.52; .P.52; .MP52)	REF1.0.N.A.010.4(.M; .P)
REF1.0.N/S.A.012.2(.M; .P; .T; .F14; .F38)	REF1.1.N/S.A.010.2(.52; .M.52; .P.52; .MP52)	REF1.0.P.B.012.1.N(.P)
REF1.0.N/S.B.015.1(.M; .P; .T)	REF1.1.N/S.A.012.1(.52; .M.52; .P.52; .MP52)	REF1.0.P.C.001.1.N(.P)
REF1.0.N/S.B.016.3(.M; .P; .T)	REF1.1.N/S.A.012.2(.52; .M.52; .P.52; .MP52)	REF1.1.P.B.012.1.52(.P)
REF1.0.N/S.B.018.1(.M; .P; .T)	REF1.1.N/S.B.015.1(.52; .M.52; .P.52; .MP52)	REF1.1.P.C.001.1.52(.P)
REF1.0.N/S.B.018.2(.M; .P; .T)	REF1.1.N/S.B.016.3(.52; .M.52; .P.52; .MP52)	REF1.1.N.A.I10.F14S
REF1.0.N/S.C.022.3(.M; .P; .T)	REF1.1.N/S.B.018.1(.52; .M.52; .P.52; .MP52)	REF1.1.N.A.I12.F14S

* Classification according to EN14276-2 Annex A – steel pipes – DN (EN ISO 6708) = 32mm

è conforme alla DIRETTIVA 2014/68/UE (attrezzature a pressione)
is in accordance with DIRECTIVE 2014/68/EU (pressure equipment)
est conforme à le DIRECTIVE 2014/68/UE (équipements sous pression)
Entspricht Druckbehälter RICHTLINIE 2014/68/EU (Druckgeräten)

Conformity and assessment procedure followed: (annex II-IV)

Refrigerant	Max working pressure	Upper/Lower T limits	DN (Sphere Passage)	PSxDN	Category	Module
Fluid Group 2	52 bar*	+150/- 40°C	≤32mm	≤1000	A 4.3	-
*salvo diversamente indicato sulla valvola / unless otherwise indicated / à moins d'indication contraire / sofern nicht anders:						.52=52bar .120=120bar

pertinenti norme armonizzate utilizzate:

relevant harmonised standards used:

normes harmonisées pertinentes appliquées:

einschlägigen harmonisierten Normen:

EN 378-2; EN 9606-3; EN 17637; EN 1593; EN 12284; EN 13445-3; EN 14276-2

Cordenons, 19/07/2016

Chief Financial Officer

Roberto Sabatino

